


# **PENTAIR GROCERY OPPORTUNITIES & TREATMENT SOLUTIONS – Case Study**

# EXISTING Point-of-Use (POU) LAYOUT



## 8 POU Water- Treatment Solutions


★ = Current possible POU Water Filtration

---

This is an actual  
outbound water line  
from a store that was  
uncovered when store  
operations were  
interrupted.



# Point-of-Entry (Central) SYSTEM



## Central Water Treatment Solution



A photograph of a water treatment system. It features a yellow tank on the left, two white tanks in the center, and three blue tanks on the right. Copper pipes and a control panel are visible at the top. The system is mounted against a light-colored wall.

High  
Efficient  
RO


**TWIN  
SOFTENER**  
101,000 grains  
capacity

20" PRE  
FILTER

Holds  
800 lbs.  
of salt

**(3) 40  
GALLON  
TANKS**  
(holding 16  
gallons of water  
per each. (1)  
holds Blend &  
(2) hold RO.

# CENTRAL SYSTEM PERFORMANCE



# CENTRAL SYSTEM PERFORMANCE – COST SAVINGS

WATER COSTS SCOTTSDALE, AZ											
Water Rates	\$ 3.70										
Sewer Rates	\$ 3.07										
Total per 1,000 gallons	\$ 6.77										
Pentair Water Costs	\$ -	\$ 14.12	\$ 16.93	\$ 15.56	\$ 18.64	\$ 70.81	\$ 81.04	\$ 73.58	\$ 91.88	\$ 78.08	\$ 61.74
Water Cost at 20% Efficient	\$ -	\$ 40.83	\$ 49.24	\$ 43.86	\$ 52.81	\$ 183.70	\$ 196.92	\$ 175.28	\$ 236.24	\$ 234.91	\$ 228.28
Water Savings Costs	\$ -	\$ 26.71	\$ 32.31	\$ 28.30	\$ 34.17	\$ 112.89	\$ 115.88	\$ 101.70	\$ 144.36	\$ 156.83	\$ 166.54

# CENTRAL SYSTEM PERFORMANCE – METER DATA

	Scottsdale Central Water Test Site Meter Readings										
Reading Date	reading 3/12/2014	19-Mar	26-Mar	2-Apr	9-Apr	7-May	5-Jun	2-Jul	7-Aug	5-Sep	2-Oct
Meter #1 (soft water supply)	3,089	5,143	7,611	9,876	12,593	22,898	34,702	45,430	58,826	70,135	78,786
Meter #2 (hard water supply)	687	718	751	785	821	976	1,143	1,283	1,458	1,682	2,151
Meter #3 (pure RO water)	877	1,815	2,997	4,020	5,288	9,618	14,248	18,452	24,168	29,713	34,518
Meter #4 (blended RO water)	1,970	2,263	2,562	2,862	3,183	4,404	5,725	6,811	8,214	9,540	10,694
Reject Water	929	1,783	2,803	3,779	4,943	9,852	15,872	21,450	27,902	32,564	35,725
REAL DATA FROM ABOVE											
Pentair Total feedwater fed		2,085	2,501	2,299	2,753	10,460	11,971	10,868	13,571	11,533	9,120
Total water produced		1,231	1,481	1,323	1,589	5,551	5,951	5,290	7,119	6,871	5,959
		59%	59%	58%	58%	53%	50%	49%	52%	60%	65%
TRADITIONAL DATA @ 20% EFFICIENT											
Total water needed 20% Efficient		6,031	7,273	6,479	7,801	27,135	29,087	25,890	34,895	34,699	33,719
Total water produced		1,231	1,481	1,323	1,589	5,551	5,951	5,290	7,119	7,119	7,119
Reject Water		4,800	5,792	5,156	6,212	21,584	23,136	20,600	27,776	27,580	26,600
		20.4%	20.4%	20.4%	20.4%	20.5%	20.5%	20.4%	20.4%	20.5%	21.1%



# ENERGY SAVINGS



## Energy Savings

(Coffee, Espresso, Iced Tea, Ice and Steam Equipment)

Years for Annuity:

Light blue indicates data entry fields

### Without Filtration

#### Annual Energy Cost for Equipment w/Scale

Electricity Rate (\$ per kWh)	\$ 0.11
<b>or</b> BTU of Equipment	0.0
<b>or</b> kW of Equipment	12.0
Hours operated per day - high volume use	6.0
Hours operated per day - low volume use	6.0
Days operated per year	365
Scale in equipment (inches)	1/8
Total Annual Electricity Cost	\$ 4,700.49

Energy Cost Over 5 years: **\$ 23,502.44**

### With Filtration

#### Annual Energy Cost for Equipment without Scale

Electricity Rate (\$ per kWh)	0.11
<b>or</b> BTU of Equipment	
<b>or</b> kW of Equipment	12.0
Hours operated per day - high volume use	6.0
Hours operated per day - low volume use	6.0
Days operated per year	365
Scale in equipment (inches)	
Total Annual Electricity Cost	\$ 3,854.40

Energy Cost Over 5 years: **\$ 19,272.00**

Energy Savings Over 5 Years: **\$ 4,230.44**

© 2011 Pentair Filtration Solutions, LLC




DELI

# DELI

- COMBI-STEAM OVEN (Alto-Shaam® 7.14 ESG)
- DISHWASHER (Hobart® AM15 or Jet-Tech® F-22)
- RETHERMALIZERS (Pitco® RTG14)

# EXISTING POINT-OF-USE (POU) LAYOUT



What we are focusing on  
Equip cost-  
 $\$30K + \$10K + \$5K = \$45K$

## 8 POU Water- Treatment Solutions

★ = Current possible POU Water Filtration



**WHEN WATER IS CONVERTED TO STEAM,  
CONTAMINANTS LEFT BEHIND CAN  
CAUSE SCALE AND CORROSION.**



# HOW WATER IMPACTS BOILER-FREE STEAM

## Scale on tubes can reduce performance

- Low steam production
- Overheating of water injection solenoid'

## Product quality and consistency

- Excessive browning of food

## Takes longer to heat due to scale

- Wastes energy
- Longer cooking cycles
- Overfiring of heat exchanges could cause failure



## Stuck floats and valves

- Under filling could result in tripping of safety, shutting down unit
- Dry firing could occur, damaging controls, elements

## Corrosion on cabinet walls and racks from chlorine and chlorides

# WATER QUALITY MINIMUM STANDARDS

## Alto-Shaam® 7.14 ESG

- **Contaminant Inlet Water Requirements**

- Free Chlorine - Less than 0.1 ppm (mg/L)
- Hardness - 30-70 ppm
- Chloride - Less than 30 ppm (mg/L)
- Ph - 7.0 to 8.5
- Silica - Less than 12 ppm (mg/L)
- Total Dissolved Solids (tds) - 50-125 ppm



# RECOMMENDATION – REVERSE OSMOSIS

## THE EVERPURE® MRS-600HE-II REVERSE OSMOSIS SYSTEM PREVENTS SCALE WHILE SIGNIFICANTLY REDUCING WATER WASTE



- The best technology for removing TDS from water
- Effective at removing hardness up to 40 grains
- Saves thousands of a gallons of water from going to drain
- Pre-filtration, filtration and reverse osmosis in one system
- Provides consistent, premium quality water at every location





**IN DISHWASHING, 467 GALLONS OF  
WATER = 1 LB OF LIMESCALE ROCK\***

\* At the national average of 300 ppm TDS

# THE IMPACT OF WATER ON DISHWASHING

**Hardness leaves spots**

**Scale can damage heating elements in booster water heaters**



**Particles can etch over time**

**Scale can clog orifices**

- Reduces flow
- Causes gaps in cleaning

**Corrosion from chlorine and chlorides attacks metals**

- It causes “rust” on surfaces
- It disintegrates parts

**Scale increases energy usage**

- As little as 1/8” can cost \$hundreds annually

# WATER QUALITY MINIMUM STANDARDS

## Jet-Tech® F-22

- To get best results, supply 140°F at all time.
- If water temperature is 120F, the dishwasher must be allowed an extra two (2) minutes between washes.
- Running pressure must not exceed 25 PSI (20 ~5)
- Water should be free of minerals and other sediments.
- If a hot water tank has to be installed to supply the dishwasher, the average rate of water consumption is 30 gallons per hour.



## Hobart® AM15

- Recommended water hardness to be less than 3 grains per gallon
- Chlorides must not exceed 50 parts per million
- “water treatment has been shown to reduce costs associated with machine cleaning, reduce the need for de-liming the dishwasher and reduce detergent usage
- Sediment, silica, Chlorides or other dissolved solids may lead to a recommendation for particulate filtration or RO treatment



# RECOMMENDATION – SOFTENING SYSTEMS

## Efficient Operation

- Meter initiated regeneration minimizes salt, water and electrical costs
- Meters are made of lead-free brass or tough, corrosion resistant plastic

## Heavy Duty Brine Tanks

- Rigid high-impact, exceptional resistance to stress cracks



## High Performance Fleck Control Valves

- Time-tested technology
- Designed to withstand rigorous fatigue testing,

## Pressure Tanks

- Fiberglass reinforced resin vessels eliminate possibility of corrosion
- Endured 250,000 cycle testing without leakage
- Meets NSF design parameters

# THE IMPACT OF WATER ON RETHERMALIZERS

## Hardness

- Reduces flow
- Causes liquid level thermostat control issues
- Over flow
- Leaves spots

## De-liming

- Use of chemicals



## Corrosion from chlorine and chlorides attacks metals

- It causes “rust” on surfaces
- It disintegrates parts

## Scale increases energy usage

- As little as 1/8” can cost \$hundreds annually

# WATER QUALITY MINIMUM STANDARDS

## Pitco®

- Temperature - 180 degrees Max
- Hardness – 2.0 Grains/gal Max
- pH – 6.5 to 8.0
- Pressure – 20 psi to 60 psi





# RECOMMENDATION – SOFTENING SYSTEMS

## Efficient Operation

- Meter initiated regeneration minimizes salt, water and electrical costs
- Meters are made of lead-free brass or tough, corrosion resistant plastic

## Heavy Duty Brine Tanks

- Rigid high-impact, exceptional resistance to stress cracks



## High Performance Fleck Control Valves


- Time-tested technology
- Designed to withstand rigorous fatigue testing,

## Pressure Tanks

- Fiberglass reinforced resin vessels eliminate possibility of corrosion
- Endured 250,000 cycle testing without leakage
- Meets NSF design parameters



# EXISTING Point-of-Use (POU) LAYOUT




What we are focusing on protecting \$45K in equipment PLUS Customer Experience

## 8 POU Water-Treatment Solutions

★ = Current possible POU Water Filtration



# Point-of-Entry (Central) SYSTEM



## Central Water Treatment Solution




# ANNUAL MAINTENANCE

Part Number	Description	Frequency of Change	Annual Cost @ List
EV313151	HEI Permeate Pump	Once a year to every other year	\$491
EV313152	HEI Inlet Boost Pump	Once a year to every other year	\$491
EV962716	7FS-BW (3)	Once/year	\$540
EV961256	MC (2)	Twice/year	\$448
EV962713	MR-600 Membrane	Every-other year	$\$856/2 = \$428$
CH30865-1	ROmate 40 Gallon Tank		\$365
		<b>ANNUAL COST</b>	<b>\$1,416</b>
Salt Usage	Next slide		


# ANNUAL MAINTENANCE – SALT USAGE

		Grains pre gallon	Gallon capacity to regeneration.	Salt usage per regeneration	40 lb bag of salt.# of regenerations	lbs salt/1000 gallons of water used.
<b><u>Water Softener Specification</u></b>		8.00	12625.00	4.00	10.00	0.32
<b>Model #:</b>	<b>9500</b>	9.00	11222.22	4.00	10.00	0.36
<b>Capacity:</b>	<b>101,000 Grains ea.</b>	10.00	10100.00	4.00	10.00	0.40
<b>Flow Rate:</b>	<b>37 GPM</b>	11.00	9181.82	4.00	10.00	0.44
<b>Peak Flow:</b>	<b>48 GPM</b>	12.00	8416.67	4.00	10.00	0.48
<b>BW Rate:</b>	<b>5.0 GPM</b>	13.00	7769.23	4.00	10.00	0.51
<b>Tank Size:</b>	<b>14" X 65" Fiberglass</b>	14.00	7214.29	4.00	10.00	0.55
<b>Brine Tank:</b>	<b>24" DIA. X 40" Poly</b>	15.00	6733.33	4.00	10.00	0.59
<b>Media Vol.:</b>	<b>3.0 FT<sup>3</sup> ea.</b>	16.00	6312.50	4.00	10.00	0.63
		17.00	5941.18	4.00	10.00	0.67
		18.00	5611.11	4.00	10.00	0.71
<b>Pipe Size:</b>		19.00	5315.79	4.00	10.00	0.75
<b>Inlet:</b>	<b>1.5" NPT</b>	20.00	5050.00	4.00	10.00	0.79
<b>Outlet:</b>	<b>1.5" NPT</b>	21.00	4809.52	4.00	10.00	0.83
<b>Drain:</b>	<b>1" NPT</b>	22.00	4590.91	4.00	10.00	0.87
		23.00	4391.30	4.00	10.00	0.91
		24.00	4208.33	4.00	10.00	0.95
<b>Weight:</b>		25.00	4040.00	4.00	10.00	0.99
<b>Shipping:</b>	<b>550 LBS.</b>	26.00	3884.62	4.00	10.00	1.03
<b>Operating:</b>	<b>LBS.</b>	27.00	3740.74	4.00	10.00	1.07
		28.00	3607.14	4.00	10.00	1.11
		29.00	3482.76	4.00	10.00	1.15
		30.00	3366.67	4.00	10.00	1.19


## BEST-PRACTICE EXAMPLE



# BEST-PRACTICE EXAMPLE




# KIOSK CONFIG I—P&ID




TITLE:		
BASE FILTRATION, KIOSK		
SIZE	DWG. NO.	REV
B		
SCALE:		SHEET 1 OF 1

# KIOSK CONFIG II—P&ID



TITLE:		
<b>BASE FILTRATION + SOFTENING, KIOSK</b>		
SIZE	DWG. NO.	REV
<b>B</b>		
SCALE:		SHEET 1 OF 1

# KIOSK CONFIG III—P&ID





# TO CAPTURE OTHER SITES AND BRANDS

---

## NEEDED

- WATER USAGE
- EQUIPMENT SET
- WATER CHARACTERISTICS

## POSSIBLE SOURCES

- UTILITY BILL
- ASSET LIST, SERVICE WO'S, ?
- WATER TEST, PNR DATABASE